

Newcon Consultants & Laboratories

(GOVERNMENT APPROVED TESTING LABORATORIES) An ISO 9001: 2015, ISO 14001: 2015, ISO 45001: 2018 Certified Laboratory

TEST REPORT

Page No.: 1 of 2

TEST REPORT No. NCL/ED-005/07/01/25

Name and Address of Customer

M/S JAI PARVATI GLOBAL SCHOOL

VILL-RAMALA DELHI, SAHARANPUR ROAD, U.P, INDIA

SAMPLING DETAILS

Sample Name

: Drinking Water

Analysis Start Date Date of Sampling

Time of Sampling

07/01/2025

: 06/01/2025

: 12:40 PM

Sampling Done By : NCL

Sampling Description Sampling Location

: Drinking Water : FROM RO WATER

Sampling Protocol **Packing Condition** : IS:3025 (P-1)

: Sealed

Analysis End Date

: 11/01/2025

Sample ID No.

NCL/ED-005/07/01/25

DATE OF REPORT: 11/01/2025

Sample Receipt Date

: 07/01/2025

Environmental Condition: 27±2°C

: 2 Ltr

Packing

Sample Quantity

: PVC CANE

TEST RESULT

S.No.	Parameters	Unit	Test Method	Result	Spacification as IS : 10500, Amd. 2018	
					Desirable Limit	Permissible Limit
1	Colour	Hazen	IS:3025 (P-4)	BDL(DL-1.0)	5.0	15.0
2	Odour		IS:3025 (P-5)	Agreeable	Agreeable	Agreeable
3	Taste		IS:3025 (P-8)	Agreeable	Agreeable	Agreeable
4	Turbidity	NTU	IS:3025 (P-10)	BDL(DL-1.0)	1.0	5.0
5	pH Value		IS:3025 (P-11)	7.22	6.5-8.5	No Relaxation
6	Total Dissolved Solids	mg/L	IS:3025 (P-16)	59	500	2000
7	Total Hardness (as CaCO3)	mg/L	IS:3025 (P-21)	8	200	600
8	Chloride (as CI)	mg/L	IS:3025 (P-32)	10	250	1000
9	Sulphate (as SO4)	mg/L	IS:3025 (P-24)	BDL(DL-2.0)	200	400
10	Fluoride (as F)	mg/L	APHA 4500-F D	BDL(DL-0.1)	1.0	1.5
11	Total Alkalinity (as CaCO3)	mg/L	IS:3025 (P-23)	12	200	600
12	Free Residual Chlorine (as Cl2)	mg/L	IS:3025 (P-26)	BDL(DL-0.1)	0.2	1.0
13	Iron (as Fe)	mg/L	IS:3025 (P-65)	BDL(DL-0.1)	1.0	No Relaxation
14	E. Coli	cfu/100 ml	IS : 15185	Absent	Shall not be detectable in	Not Specified

ED-005/07/01/25-1



SONU

Checked by

FOR NEWCON CONSULTANTS & LABORATORIES RVATI GLOBAL SCHOOL

authorized Signator HAIRMAN

1. The test report refers only to the particular sample/s submitted for testing and listed parameters.

2. Endorsement of the same is neither inferred nor implied.

3. Laboratory shall maintain the confidentiality of all information related to the samples & test reports.

5. The report is not to be produced wholly or in part without prior permission of the Managing Partner. All disputes subject to Ghaziabad Jurisaiction.

Jai Parvati Global Schoo

Ramala (Baghpat) U.P.



Newcon Consultants & Laboratories

(GOVERNMENT APPROVED TESTING LABORATORIES)
An ISO 9001: 2015, ISO 14001: 2015, ISO 45001: 2018 Certified Laboratory

Page No.: 2 of 2

TEST REPORT No. NCL/ED-005/07/01/25

DATE OF REPORT: 11/01/2025

S.No.	Parameters	Unit	Test Method	Result	Spacification as IS : 10500, Amd. 2018	
					Desirable Limit	Permissible Limit
14					any 100 ml sample	
15	Total Coliform	cfu/100 ml	IS : 15185	Absent	Shall not be detectable in any 100 ml sample	Not Specified

End of Report

Remarks: BDL=Below Detection Limit.

ED-005/07/01/25-2



ISHA TYAGI Jr. Atolyst Checked by



FOR NEWCON CONSULTANTS & LABORATORIES

Authorized Signato

1. The test report refers only to the particular sample/s submitted for testing and listed parameters.

2. Endorsement of the same is neither inferred nor implied.

Laboratory shall maintain the confidentiality of all information related to the samples & test reports.
 Complaints about this report should be communicated within 10 days of the issue date of this report.

5. The report is not to be produced wholly or in part without prior permission of the Managing Partner. All disputes subject to Ghaziabad Jurisdiction.

E-mail: newconlab@gmail.com, newconlabfinance@gmail.com